



- NOTES:
1. Refer to the W.S.D.O.T. Standard Specifications for Side Sewers in Section 7-18.
 2. Refer to W.S.D.O.T. Standard Specifications Section 7-08.3(1)C for pipe bedding requirements, and Standard Details 4-01, 4-02 and 4-03 for Pipe Zone Bedding material.
 3. Bedding and grade shall be established prior to pipe being placed in trench.
 4. For 1-1/4" service use 2" x 1-1/4" brass bushing for 2" tap. For 2" service, omit bushing.
 5. Sanitary sewer manhole upstream and two manholes downstream must be coated with Ravens 405.

3-12GP
STD. PLAN NO.

APPROVED BY	REVISED DATE	CITY OF CENTRALIA FORCE MAIN SEWER LATERAL SERVICE CONNECTION
CITY ENGINEER	06-2022	
2022 Standard Drawings		