



1 PLACE CONSTRUCTION GEOTEXTILE FOR SOIL STABILIZATION AND A MINIMUM OF 0.15' CRUSHED ROCK UNDER THE SPALLS, FROM THE EDGE OF THE EXISTING ROADWAY TO THE RADIUS RETURNS, OR AS DIRECTED BY THE ENGINEER.

AS REQUIRED ~ 100' MIN., EXCEPT MAY BE REDUCED TO 50' MIN. FOR SITES WITH LESS THAN ONE ACRE OF EXPOSED SOIL.

1' - 0" MIN.

PROVIDE FULL WIDTH OF INGRESS / EGRESS AREA 15' - 0" MIN.

ISOMETRIC VIEW

9-10	STD. PLAN NO.			
		APPROVED BY	REVISED DATE	CITY OF CENTRALIA TEMPORARY CONSTRUCTION ENTRANCE
			06/2017	
		CITY ENGINEER		
2022 Standard Drawings				