



TOP VIEW




SIDE VIEW

TEE




TOP VIEW




SIDE VIEW

CROSS




TOP VIEW




SIDE VIEW


GATE VALVE




WYE




HORIZ. BEND




TEE WITH
PLUG




CROSS WITH
PLUG



CROSS WITH
PLUGS



PLUG OR CAP



45° - 90°
VERT. BEND

NOTES:

1. CONCRETE THRUST BLOCKING TO BE POURED AGAINST UNDISTURBED EARTH.
2. PLASTIC BARRIER (12 MIL.), SHALL BE PLACED BETWEEN ALL THRUST BLOCKS & FITTINGS
3. ANCHOR REBAR SHALL BE #8 ON 12" DIA. AND LESS WITH 30" EMBEDMENT, #8 ON 16"-24" DIAMETER WITH 36" EMBEDMENT.
4. ALL FITTINGS TO BE MJ-MEGA LUG RETAINER GLANDS
5. PLUGS TO BE MINIMUM OF 5' FROM TEE, WYE OR CROSS ON VALVE
6. ALL MECHANICAL BOLTS TO FITTINGS SHALL HAVE ANTI-SEIZE COMPOUND APPLIED TO THE BOLTS
7. NO CONCRETE WILL COME IN CONTACT WITH ANY MECHANICAL JOINTS

APPROVED BY	REVISED DATE	CITY OF CENTRALIA	STD. PLAN NO.
CITY ENGINEER	06/2017		2-10
2022 Standard Drawings			