



**FIBERGLASS ACCESS LID
ACTUAL VIEW**

1. Top of lid to be flush with existing ground or as directed by City.
2. Bolt Catches required per ea. bolt.



FIBERGLASS ACCESS LIDS

WITH RECESSED S.S. LID BOLTS AND GASKETED SEAL IN LID.



**FIBERGLASS ACCESS LID
CUTAWAY VIEW**

BOLT CATCHES

**FINISHED
GRADE**

**GALVANIZED 90°
STREET ELBOW
WITH SCREENED
OPENING**

**COMPACTED BACKFILL ALL
AROUND PVC RISER PIPE**

**AIR and VACUUM VALVE
APCO series 140
1/2 INCH THRU 3 INCH
OUTLETS ARE NPT THREADED**

30' PVC RIBBED RISER

**NIBCO - CLASS 150
BRONZE ANGLE VALVE
T-335 w/ BRASS HANDLE**

**1/3 CY GRAVEL
BACKFILL**

BRASS OR HDPE PIPE

BRASS 90° ELBOW

BRASS NIPPLE

CORPORATION STOP

**ROMAC 202N
NYLON COATED
SERVICE SADDLE
DOUBLE STRAP, SS**

CONCRETE BLOCK

NOTES:

1. CORPORATION STOP, PIPE, FITTINGS, ANGLE VALVE, AND COMBINATION AIR and VACUUM VALVE INLET TO BE THE FOLLOWING:
1" DIAMETER FOR 6" MAIN
1.5" DIAMETER FOR 8" MAIN
2" DIAMETER FOR 10" AND ABOVE
2. USE APPROVED JOINTING COMPOUND ON ALL THREADED CONNECTIONS OR TEFLON TAPE
3. LIMIT OF PAY ITEM INCLUDES SERVICE SADDLE.

LIMIT OF PAY ITEM

APPROVED BY	REVISED DATE	CITY OF CENTRALIA	STD. PLAN NO.
CITY ENGINEER	06/2017	AIR and VACUUM VALVE ASSEMBLY	2-13
2022 Standard Drawings			