



**NOTES:**

1. CONCRETE THRUST BLOCKING TO BE POURED AGAINST UNDISTURBED EARTH.
2. PLASTIC BARRIER ( 12 MIL.), SHALL BE PLACED BETWEEN ALL THRUST BLOCKS & FITTINGS
3. ANCHOR REBAR SHALL BE #8 ON 12" DIA. AND LESS WITH 30" EMBEDMENT, #8 ON 16"-24" DIAMETER WITH 36" EMBEDMENT.
4. ALL FITTINGS TO BE MJ-MEGA LUG RETAINER GLANDS
5. PLUGS TO BE MINIMUM OF 5' FROM TEE, WYE OR CROSS ON VALVE
6. ALL MECHANICAL BOLTS TO FITTINGS SHALL HAVE ANTI-SEIZE COMPOUND APPLIED TO THE BOLTS
7. NO CONCRETE WILL COME IN CONTACT WITH ANY MECHANICAL JOINTS

APPROVED BY	REVISED DATE	<b>CITY OF CENTRALIA</b>	STD. PLAN NO.
CITY ENGINEER	06/2017	<b>STANDARD BLOCKING DETAIL</b>	2-10