



NOTES:

1. Refer to the W.S.D.O.T. Standard Specifications for Side Sewers in Section 7-18.
2. Refer to W.S.D.O.T. Standard Specifications Section 7-08.3(1)C for pipe bedding requirements, and Standard Details 4-01, 4-02 and 4-03 for Pipe Zone Bedding material.
3. Bedding and grade shall be established prior to pipe being placed in trench.
4. For 1-1/4" service use 2" x 1-1/4" brass bushing for 2" tap
5. For 2" service, omit bushing

3-12GP
 STD. PLAN NO.

APPROVED BY	REVISED DATE
CITY ENGINEER	06-2017

CITY OF CENTRALIA
FORCE MAIN
SEWER LATERAL
SERVICE CONNECTION