



*GENERAL NOTES:*

1. EXPANSION JOINT MATERIAL TO BE 3/8" THICK PREMOLDED JOINT FILLER FULL THICKNESS OF CONCRETE. SEE SIDEWALK DETAILS (5-01) FOR EXPANSION JOINT SPACING.
2. FORM AND SUBGRADE INSPECTION REQUIRED BEFORE POURING CONCRETE.

APPROVED BY	REVISED DATE	<b>CITY OF CENTRALIA</b>	STD. PLAN NO.
CITY ENGINEER	<b>06/2017</b>	<b>CEMENT CONCRETE CURB and GUTTER</b>	<b>5-02</b>